



July 25, 2019

2020-02 PWP-WA-2019-279
Reno Sparks Livestock Events Center
Pavement Rehabilitation Project
1350 North Wells Ave.
Reno, Nevada 89512

ADDENDUM NO.2

This Addendum forms a part of the Contract Documents and modifies the original Bidding Specification, drawings and details dated May 3, 2019, as described below. Bidder shall acknowledge receipt of this Addendum where corresponding information is requested on the Proposal Form. Failure to make such acknowledgment may subject the Bidder to disqualification.

This Addendum consists of the following changes to the Proposal Form:

Bidders must omit the cost of the Stone Undercut (1-1/4") in the total amount of the Base Bid Grand Total. We are requiring a unit cost for the Crushed Aggregate Base Course or Graded Aggregate Base to be included in the proposal. This unit cost must include the total cost per ton for excavation and disposal of existing material, furnishing and installing the material, and proper compaction with fine grading. Contractor will be responsible for providing Load Tickets to verify the amount of material in the event material is needed. This unit cost will be billed as a Change Order.

This Addendum only applies to the work detailed in 2.41 Asphalt Pavement Restoration-3" Depth. All work must be performed per specifications detailed in RFP#2020-02 PWP-WA-2019-279.

0.70 STONE UNDERCUT (1-1/4")

This item shall include the removal and disposal of unsuitable material which is excavated below subgrade (EBS). Work shall include the excavation and disposal of existing material, furnishing and installing the replacement material, and proper compaction with fine grading. This item is not intended for areas that become unstable because of the Contractor's inability to place pavement in a timely manner.

Replacement shall be with a well-graded Crushed Aggregate Base Course (CABC) or Graded Aggregate Base (GAB) meeting the following gradation:

Sieve Size	Percent Passing
	1-1/4" Minus
3" (75mm)	-
1-1/2"(37.5mm)	100
1-1/4"	95 to 100
1" (25mm)	-
3/4" (19mm)	70 to 93
3/8"	42 to 80

No. 4	25 to 63
No. 10	16 to 48
No. 40	8 to 28
No. 200	2 to 12

Alternate gradations must meet Standard Specification requirement and be approved by the Consultant. Alternate materials, such as recycled concrete or asphalt, may be considered and negotiated for use after award of the project.

The Contractor shall provide a fully loaded dump truck or water truck for proof rolling. The proof roll shall be conducted over the entire area or as agreed to with the Consultant. Unstable areas that cannot be reworked, recompacted or stabilized and for which alternate measures are not conducive or reasonable shall be undercut. When possible, slope bottom of excavation for drainage.

The Contractor shall fine grade and compact the crushed aggregate base course. Compaction shall be performed with a single drum vibratory compactor having a minimum operating static weight of 12,000 lb. and a minimum centrifugal force of 22,000 lb. In the event the material is deficient in moisture content for readily obtaining the necessary density, it shall be moistened to the degree necessary by means of approved equipment. The compaction operation shall continue until the Consultant observes no visible displacement of material laterally or longitudinally under the compaction or hauling equipment.

Payment for this item of work shall be made at the contract unit price for the completed quantity of 0.70 Stone Undercut (per ton of stone installed), as verified by the Consultant

**- End of Addendum No. 2 -
APPLICABLE TO THE PROJECT MANUAL:**