

ADDENDUM NUMBER 1

DATE: June 15, 2022

PROJECT: Reno-Sparks Convention & Visitors Authority
2022-04 PWP-WA-2022-358 Reno-Sparks Convention Center Video Security Camera Upgrade

SUBJECT: Addendum Number 1

FROM: Brian Cuneo, PK Electrical, Inc.

ATTACHMENTS: None

BIDDERS NOTES:

1. The Contractor shall acknowledge receipt of this Addendum Number 1 on the Bid Proposal Form. All terms and provisions of the Bid Documents shall apply to this Addendum.

ADDENDUM ITEMS:

- ITEM #1** **Detail 4/T0.02 – Control Room Workstations:** Extended warranty part number for control room workstations is incorrect. Correct part number is RM6-WKS-WARR-EXTENDED-2YR.
- ITEM #2** **Details 5,6/T0.02 – Network Video Recorder Server Cables:** For each server, provide qty (2) 3-meter OM3 multimode fiber optic patch cables with duplex LC connectors (Corning Fiber Part Number 050502T5120003M or equal).

END OF ADDENDUM NUMBER 1