



P.O. Box 837
Reno, NV 89504 USA
t: 775.827.7768
VisitRenoTahoe.com

Subject: Request for Proposal 2022-05
Response to Questions submitted

RFP Title: **Reno-Sparks Convention Center Sections D3
and U1 Roof Refurbishment Project**

Date of RFP Release: June 13, 2022

Bid Responses Due: July 1, 2022, 1:00 PM (PST)

Bid Opening Time: July 1, 2022, 1:10 PM (PDT)

Contact: Jose Martinez/Director of Facilities Operations

The Reno-Sparks Convention and Visitors Authority received the following questions in regard to RFP 2022-05. Below are the questions received (Black) and the Authority's responses (Blue).

1. Both the U1 and D3 roofs calls out detail "SD-SBF1". After field verification it does not appear that this detail would apply to either roof section due to the fact that there is no existing reglet or counter flashing. Please confirm and thanks.

It is pretty close follow detail to term bar three course and apply reinforced coating above term bar to just under metal coping cap.